

Shannon Kian Zareh, Charles E. Miller, J. Kent Wallace
Jet Propulsion Laboratory, California Institute of Technology
ESTF2019 Meeting, NASA Ames

13 June 2019

## The CARBO Team



- Charles Miller (PI)
- J. Kent Wallace
- Yuri Beregovski
- Mayer Rud
- Randy Bartos
- Jim McGuire
- Tom Pagano
- Dan Wilson
- Cynthia B. Brooks UT Austin

- Dan Jaffe UT Austin
- Andre Wong
- Didier Keymeulen
- Peter Sullivan
- Elliott Liggett
- Michael Bernas
- Amy Mainzer
- Annmarie Eldering
- Dejian Fu

## Overview of Presentation



- Programmatic overview
- CARBO instrument concept
- Instrument architecture
- Key technologies
  - Immersion gratings
  - Polarization sensing
  - Large format CHROMA-D/GeoSnap focal plane arrays
- Instrument radiometric performance estimate
- Summary and conclusion

# Programmatic Overview



- Funded by Instrument Incubator Program (IIP)
  - NASA's Earth Science Technology Office (ESTO)
- Institutions:
  - Jet Propulsion Laboratory
  - University of Texas at Austin
  - Caltech


#### • Goal:

- Develop a new, more capable suite of instruments to measure the green house gasses for better understanding of carbon climate.
- Advance new technology immersion gratings and modular instrument architecture.

## CARBO Instrument Concept



- Wide-FOV imaging spectrometer
  - FOV: 12 degree with 2k x 2k Geosnap
  - Ground swath: 148 km
- Low Earth orbit (LEO)
- Spatial resolution of 2 km x 2 km
- Weekly revisit rate
- Contiguous spatial sampling
- Adds CH4 and CO to the CO2 and Solar Induced Fluorescence (SIF) measurements pioneered by the Orbiting Carbon Observatory (OCO-2/3)
  - increases ability to disentangle carbon fluxes into their constituent components
- Modular architecture
- New technology
  - Immersion grating
  - CHROMA-D/GeoSnap focal plane array: a large-format, low-noise detector optimized for imaging spectroscopy
  - Polarization sensing



# CARBO Design Requirements





| CARBO<br>Requirements                            | Design, Build, Field Test  |                                    | Design                             |                                    |
|--|--|------------------------------------|------------------------------------|------------------------------------|
|  | Instrument   | Instrument                         | Instrument                         | Instrument                         |
|  | 1  | 2                                  | 3                                  | 4                                  |
| Spectral Range (nm)                              | 745 -772   | 1598 – 1659                        | 2045 - 2080                        | 2305 - 2350                        |
|  | $(\Delta \lambda = 27 \text{ nm})$   | $(\Delta \lambda = 61 \text{ nm})$ | $(\Delta \lambda = 35 \text{ nm})$ | $(\Delta \lambda = 45 \text{ nm})$ |
| Measurement Targets                              | O <sub>2</sub> , SIF   | $CO_2, CH_4$                       | $CO_2$                             | $CO, CH_4$                         |
| SNR @ 5% albedo<br>and 50° SZA                   | > 300  | > 350                              | > 150                              | >100                               |
| Spectral resolution FWHM (nm) at $\lambda_{ave}$ | 0.05   | 0.15                               | 0.10                               | 0.12                               |
| Spectral Resolving power at $\lambda_{max}$      | 15,440   | 11,060                             | 20,800                             | 19,583                             |
| <b>Required Precision</b>                        | X <sub>CO2</sub> <1.5 ppm, X <sub>CH4</sub> <7 ppb, X <sub>CO</sub> <5 ppb, SIF <20% |                                    |                                    |                                    |

- Nominal bright case SNR @ SZA = 35 deg and albedo = 30%
- The SNR case for SZA = 50 deg and 5% albedo is the driving/limiting dark case


## Simulated CARBO Instrument Performance








## Instrument 2



#### Instrument 4



# Conceptual Opto-Mechanical Layout



#### Instrument 1

(745 – 772 nm, Oxygen-A band and SIF Remote Sensing)

Telescope aperture diameter: 25 mm

Telescope focal length: 52.8 mm

■ Telescope F/# : 2.11

Ground Sample Distance: 240 m


Slit width: 36 um

Wavelength range : 27 nm

Spectral Resolution: 0.05 nm

R = 15,400

Spectral dispersion: 1080 pixels



# Conceptual Opto-Mechanical Layout



#### Instrument 2

(1595 – 1659 nm, CO2 and CH4 Remote Sensing)

Telescope aperture diameter: 35 mm

Telescope focal length: 75.18 mm

Telescope F/# : 2.11

Ground Sample Distance: 168 m


Slit width: 36 um

Wavelength range: 61 nm

Spectral Resolution: 0.15 nm


R = 11,060

Spectral dispersion: 814 pixels




# Instrument 2 Optical Design & Optomechanical Packaging






# Instrument 2 Optical Design & Optomechanical Packaging







# Instrument 2











Overall Dimensions: 580 mm X 260 mm X 526 mm

 Preliminary Thermal Model Geometry (4/19/19)

# Instrument 2








# Instrument 1 Optical Design & Optomechanical Packaging







# CARBO Critical Technology:


Si Immersion Gratings



- Si immersion gratings enable CARBO NIR instruments to take full advantage of large format FPAs
- Significantly decreases instrument size
- Up to 15 degree field of view
- Excellent optical performance across entire FPA









# Key Technologies: Immersion Grating




- Si immersion gratings enable CARBO NIR instruments to take full advantage of large format FPAs
- Significantly decreases instrument size
- Up to 15 degree field of view
- Excellent optical performance across entire FPA






Groove structure

ESTF2019



Glass prism with polymer grating




Grayscale E-beam Patterned Grating Etched into Silicon Prism (Grating diameter 55 mm, Prism ARcoated on non-grating side)

13 June 2019

# Immersion Grating Correction of Anamorphic Compression



### Immersion Grating Benefit: Reduction in Anamorphic Compression




- A planar grating causes anamorphic beam compression
- An immersed grating can be designed so that the anamorphism is largely compensated by the prism
- Anamorphic correction allows for more symmetric PSF over wavelength, which enables more uniform sampling over the detector

# Immersion Grating and Spectral Resolving Power




### Immersion Grating Benefit: Improvement in Resolving Power Uniformity Across Wavelength




# Key Technology: Simultaneous Polarization Sensing



- In general, all gratings are sensitive to polarization states: different grating efficiency for each polarization state → lose photons
- CARBO utilizes an optical design that is insensitive to polarization state, with high grating efficiency
- Enhances sensitivity to surface polarization effects, aerosol composition (better constraints on scattering parameters) and better discrimination of atmospheric and surface scattering.







# New Technology: Large Format FPA CHROMA-D/GeoSnap



- Latest infrared focal plane technologies from Teledyne Imaging Sensors (TIS)
- 18 um pixel pitch HgCdTe detector hybridized to digital ROIC
- Variable array sizes of 2k x 500 (Chroma-D) and 2k x 2k (GeoSnap)
- Unit cell with 2 gains / full well
  - 100 ke- and 1Me- or 180 ke- and 2.7 Me-
- On-chip digitization
  - without the need for complex analog-to-digital electronics supporting the FPA, the GeoSnap/CHROMA-D allows a simpler overall design for the CARBO instrument
- Snapshot, integrated while read
- Full frame rate: 120 Hz for 2k x 2k






Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not constitute or imply its endorsement by the United States Government or the Jet Propulsion Laboratory, California Institute of Technology.

## Radiometric Performance Estimate



- The engineering design work is guided by Radiometric performance estimate of signal-to-noise analysis, which is a function of:
  - Radiometry over the band
  - Observational Scenarios (albedo and SZA)
  - Instrument parameters
  - Throughput of the system
  - FPA noise performance
  - Integration time
  - Fabrication constraints



# Summary and Conclusion



- CARBO is a tech demo instrument, funded by NASA's Instrument Incubator Program (IIP)
- CARBO is modular with a suite of 4 instruments (758nm, 1628nm, 2062nm, 2327nm)
  - Wide-FOV from LEO at 12 degrees (148 km ground swath)
  - CO2, CH4, CO and enhanced SIF measurements
  - 2x2 km<sup>2</sup> spatial resolution
  - 0.05 nm 0.15 nm spectral resolution
  - Weekly revisit rate
  - Compact design, common form factor, share one platform
- CARBO advances the following key technologies:
  - Immersion gratings
  - Large format FPA, GeoSnap/CHROMA-D
  - Simultaneous polarization sensing
  - Modular architecture, same form factor, on a common platform
- JPL designs, builds and fields instruments 2, and designs instruments 1, 3 and 4